



TRANSFORMER KVA RATING	DIMENSIONS IN FEET		
	A	B	
0-75	10	14	
76-333	20	20	
334-LARGER	30	30	

## NOTES

1. IF THE BUILDING HAS AN OVERHANG AND IS 3 OR LESS FLOORS IN HEIGHT ABOVE THE GROUND, THE "A" CLEARANCE IS MEASURED FROM A POINT BELOW THE EDGE OF THE OVERHANG.
2. IF THE BUILDING HAS AN OVERHANG AND IS 4 OR MORE FLOORS IN HEIGHT ABOVE THE GROUND, THE "A" CLEARANCE MAY BE MEASURED FROM THE BUILDING WALL.
3. FIRE ESCAPES, OUTSIDE STAIRS, AND COVERED WALKWAYS ATTACHED TO OR BETWEEN BUILDINGS, SHALL BE CONSIDERED AS PART OF THE BUILDING.
4. IF CLEARANCE LISTED ABOVE CAN NOT OBTAINED SEE DRAWING SPEC-0000020.



# ARKANSAS VALLEY ELECTRIC COOPERATIVE COOPERATION

# TITLE LOCATION OF PADMOUNT TRANSFORMERS FROM BUILDINGS

DWG#: SPEC-0000019	DATE: 07.03.17	SCALE: NTS
DRAWN BY: JDC	REV: 0	REV. DATE: N/A