



NOTES

1. MEMBER PROVIDES AND INSTALLS: CONDUIT, SUPPORT BEAM, DISCONNECT SWITCH, GROUND ROD AND WIRE, AND ALL RELATED MATERIALS. METER BASE IS SUPPLIED BY AVECC AND INSTALLED BY THE MEMBER/ELECTRICIAN. ALL WORK SHALL COMPLY WITH COOPERATIVE STANDARDS, THE CURRENT VERSION OF THE NATIONAL ELECTRIC CODE, AND AUTHORITIES HAVING JURISDICTION.
2. COOPERATIVE PROVIDES AND INSTALLS METER, TRANSFORMER, PRIMARY CONDUCTORS TO THE TRANSFORMER, AND TERMINATES BOTH PRIMARY AND SECONDARY CONDUCTORS WITHIN THE TRANSFORMER.
3. THIS SERVICE SHALL BE INSTALLED AT A LOCATION MUTUALLY AGREED UPON BY THE MEMBER AND THE COOPERATIVE.
4. ALL CONDUITS SHALL BE ELECTRICAL GRADE PVC, EMC, IMC, OR RMC. ALL CONDUIT CONNECTIONS SHALL BE RAIN-TIGHT.
5. MINIMUM OF 3 FEET OF CLEARANCE BETWEEN ELECTRIC METER AND GAS METER.
6. THE SERVICE ENTRANCE PANEL/DISCONNECT SHALL BE GROUNDED PER THE NATIONAL ELECTRIC CODE BEFORE COOPERATIVE WILL INSTALL SERVICE AND METER.
7. SERVICE ENTRANCE DISCONNECTS SHALL BE EITHER FUSED OR BREAKER TYPE, RATED FOR SERVICE ENTRANCE.
8. POWER SUPPLY FROM THE MAIN DISCONNECT SHALL MEET THE REQUIREMENTS OF SECTION 550 OF THE NATIONAL ELECTRIC CODE (NEC).

**MAKE AN ARKANSAS ONE CALL
48 HOURS BEFORE YOU DIG
DIAL 1-800-482-8998**

IT SHALL BE A MEMBER'S
RESPONSIBILITY TO STAY CLEAR
OF ALL UNDERGROUND FACILITIES

NOTICE

THIS DRAWING ILLUSTRATES AVECC REQUIREMENTS ONLY, AND IS NOT INTENDED TO BE A COMPREHENSIVE GUIDE FOR THE INSTALLATION OF AN ELECTRICAL SERVICE. TO INSURE A SAFE, QUALITY INSTALLATION THAT COMPLIES WITH THE NATIONAL ELECTRICAL CODE, AND LOCAL CODE REQUIREMENTS; THE COOPERATIVE RECOMMENDS THAT ALL WORK BE DONE BY A QUALIFIED, LICENSED ELECTRICAL CONTRACTOR.



ARKANSAS VALLEY ELECTRIC
COOPERATIVE COOPERATION

TITLE
UNDERGROUND TEMPORARY
POLE INSTALLATION

DWG#: SPEC-000009	DATE: 06.06.17	SCALE: NTS
DRAWN BY: JDC	REV: 0	REV. DATE: N/A